



ANNUAL REPORT 2018

| | |
|--|--|
| Drinking-Water System Number: | 260035230 |
| Drinking-Water System Name: | Prince Township Office Well Supply |
| Drinking-Water System Owner: | Prince Township |
| Drinking-Water System Category: | Small Municipal Non-Residential - Designated |
| Period being reported: | Jan. 1, 2018 – Dec. 31, 2018 |

| | |
|--|---|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u> N/A</p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; width: fit-content;">Prince Township Office</div> | <p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? N/A Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? N/A Yes [] No []</p> |
|--|---|

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system: N/A

| Drinking Water System Name | Drinking Water System Number |
|----------------------------|------------------------------|
| | |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
N/A Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge. N/A

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method

Describe your Drinking-Water System

The Prince Township Office water supply is ground water drawn from a drilled well through the use of a submersible pump. The water passes through a 5-micron and a 1-micron absolute cartridge filter and a Sterilight Ultraviolet Disinfection unit that is NSF/ANSI 55 approved, before entering the distribution system. The system is continuously monitored by an alarm system. If any alarm conditions occur, the alarm system will call the Sault Ste. Marie WTP which is staffed 24 hours per day.

List all water treatment chemicals used over this reporting period

N/A

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Replacement filters, sleeves, and sensors.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre N/A

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|-----------|--------|-----------------|-------------------|------------------------|
| | | | | | |
| | | | | | |
| | | | | | |

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|--------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw | 12 | 0 | 0 | - | - |
| Treated | n/a | | | | |
| Distribution | 45 | 0 | 0 | 45 | 0 - 55 |



Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) |
|-----------------------------------|------------------------|----------------------------------|
| Turbidity (Raw) | 12 | 0.10 - 1.23 |
| Turbidity (Dist.) | 45 | 0.07 - 0.93 |
| Chlorine | N/A | - |
| Fluoride (If the DWS fluoridates) | N/A | - |

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument. N/A

| Date of legal instrument issued | Parameter | Date Sampled | Result | Unit of Measure |
|---------------------------------|-----------|--------------|--------|-----------------|
| | | | | |
| | | | | |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|-----------|-------------|--------------|-----------------|------------|
| Antimony | 05-Jun-17 | <0.0006 | mg/L | no |
| Arsenic | 05-Jun-17 | <0.001 | mg/L | no |
| Barium | 05-Jun-17 | 0.087 | mg/L | no |
| Boron | 05-Jun-17 | <0.05 | mg/L | no |
| Cadmium | 05-Jun-17 | <0.0001 | mg/L | no |
| Chromium | 05-Jun-17 | <0.001 | mg/L | no |
| Mercury | 05-Jun-17 | <0.0001 | mg/L | no |
| Selenium | 05-Jun-17 | <0.001 | mg/L | no |
| Sodium | 05-Jun-17 | 5.43 | mg/L | no |
| Uranium | 05-Jun-17 | <0.02 | mg/L | no |
| Fluoride | 05-Jun-17 | 0.051 | mg/L | no |

| Parameter | 1 st Quarter | 2 nd Quarter | 3 rd Quarter | 4 th Quarter |
|-----------|-------------------------|-------------------------|-------------------------|-------------------------|
| Date | 08-Jan-18 | 07-May-18 | 24-Jul-18 | 16-Oct-18 |
| Nitrite | <0.010 | <0.010 | <0.010 | <0.010 |
| Nitrate | <0.020 | <0.020 | <0.020 | <0.020 |



Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

| Location Type | Number of Samples | Range of Lead Results (min#) – (max #) | Number of Exceedances |
|-----------------------------------|-------------------|--|-----------------------|
| Plumbing (Prince Resource Centre) | 2 | 0 | 0 |
| | | | |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|--|-------------|--------------|-----------------|------------|
| Alachlor | 05-Jun-17 | <0.0001 | mg/L | no |
| Atrazine + N-dealkylated metabolites | 05-Jun-17 | <0.0002 | mg/L | no |
| Azinphos-methyl | 05-Jun-17 | <0.0001 | mg/L | no |
| Benzene | 05-Jun-17 | <0.0005 | mg/L | no |
| Benzo(a)pyrene | 05-Jun-17 | <0.00001 | mg/L | no |
| Bromoxynil | 05-Jun-17 | <0.0002 | mg/L | no |
| Carbaryl | 05-Jun-17 | <0.0002 | mg/L | no |
| Carbofuran | 05-Jun-17 | <0.0002 | mg/L | no |
| Carbon Tetrachloride | 05-Jun-17 | <0.0002 | mg/L | no |
| Chlorpyrifos | 05-Jun-17 | <0.0001 | mg/L | no |
| Diazinon | 05-Jun-17 | <0.0001 | mg/L | no |
| Dicamba | 05-Jun-17 | <0.0002 | mg/L | no |
| 1,2-Dichlorobenzene | 05-Jun-17 | <0.0005 | mg/L | no |
| 1,4-Dichlorobenzene | 05-Jun-17 | <0.0005 | mg/L | no |
| 1,2-Dichloroethane | 05-Jun-17 | <0.0005 | mg/L | no |
| 1,1-Dichloroethylene (vinylidene chloride) | 05-Jun-17 | <0.0005 | mg/L | no |
| Dichloromethane | 05-Jun-17 | <0.005 | mg/L | no |
| 2-4 Dichlorophenol | 05-Jun-17 | <0.0003 | mg/L | no |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | 05-Jun-17 | <0.0002 | mg/L | no |
| Diclofop-methyl | 05-Jun-17 | <0.0002 | mg/L | no |
| Dimethoate | 05-Jun-17 | <0.0001 | mg/L | no |
| Diquat | 05-Jun-17 | <0.001 | mg/L | no |
| Diuron | 05-Jun-17 | <0.001 | mg/L | no |
| Glyphosate | 05-Jun-17 | <0.005 | mg/L | no |
| Malathion | 05-Jun-17 | <0.0001 | mg/L | no |
| 2-methyl-4-chlorophenoxyacetic acid(MCPA) | 05-Jun-17 | <0.0001 | mg/L | no |
| Metribuzin | 05-Jun-17 | <0.0001 | mg/L | no |
| Monochlorobenzene | 05-Jun-17 | <0.0001 | mg/L | no |
| Paraquat | 05-Jun-17 | <0.0005 | mg/L | no |
| Pentachlorophenol | 05-Jun-17 | <0.0002 | mg/L | no |
| Phorate | 05-Jun-17 | <0.001 | mg/L | no |
| Picloram | 05-Jun-17 | <0.0005 | mg/L | no |
| Polychlorinated Biphenyls(PCB) | 05-Jun-17 | <0.0001 | mg/L | no |
| Prometryne | 05-Jun-17 | <0.0002 | mg/L | no |
| Simazine | 05-Jun-17 | <0.0001 | mg/L | no |



| | | | | |
|--|-----------|---------|------|----|
| THM (NOTE: show latest annual average) | N/A | - | - | - |
| Terbufos | 05-Jun-17 | <0.0002 | mg/L | no |
| Tetrachloroethylene | 05-Jun-17 | <0.0005 | mg/L | no |
| 2,3,4,6-Tetrachlorophenol | 05-Jun-17 | <0.0005 | mg/L | no |
| Triallate | 05-Jun-17 | <0.0001 | mg/L | no |
| Trichloroethylene | 05-Jun-17 | <0.0005 | mg/L | no |
| 2,4,6-Trichlorophenol | 05-Jun-17 | <0.0005 | mg/L | no |
| Trifluralin | 05-Jun-17 | <0.0001 | mg/L | no |
| Vinyl Chloride | 05-Jun-17 | <0.0002 | mg/L | no |

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. N/A

| Parameter | Result Value | Unit of Measure | Date of Sample |
|------------------|---------------------|------------------------|-----------------------|
| | | | |
| | | | |